

BS EN 31:2011



BSI Standards Publication

Wash basins — Connecting dimensions

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

National foreword

This British Standard is the UK implementation of EN 31:2011. It supersedes BS EN 111:2003 and BS EN 31:1999 and BS EN 32:1999 which are withdrawn.

The UK participation in its preparation was entrusted to Technical Committee B/503, Sanitary appliances.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© BSI 2011

ISBN 978 0 580 65146 5

ICS 91.140.70

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 September 2011.

Amendments issued since publication

Date	Text affected
------	---------------

EUROPEAN STANDARD

EN 31

NORME EUROPÉENNE

EUROPÄISCHE NORM

September 2011

ICS 91.140.70

Supersedes EN 111:2003, EN 31:1998, EN 32:1998

English Version

Wash basins - Connecting dimensions

Lavabos - Cotes de raccordement

Waschbecken - Anschlussmaße

This European Standard was approved by CEN on 29 July 2011.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2011 CEN All rights of exploitation in any form and by any means reserved
worldwide for CEN national Members.

Ref. No. EN 31:2011: E

Contents		Page
Foreword.....		3
1	Scope	4
2	Normative references	4
3	Tap holes	4
3.1	General.....	4
3.2	Connecting dimensions of wash basins with one central tap hole.....	4
3.3	Connecting dimensions of wash basins with side tap hole(s)	6
3.4	Connecting dimensions of wash basins with three tap holes	7
4	Waste outlet hole(s).....	9
4.1	Connecting dimensions of waste outlet hole(s) with integral overflow.....	9
4.2	Connecting dimensions of waste outlet hole without integral overflow	10
5	Fixing dimensions of wall-hung wash basins	11
Annex A (informative) Example of gauge for measuring the connecting dimensions of waste outlet holes		13

Foreword

This document (EN 31:2011) has been prepared by Technical Committee CEN/TC 163 “Sanitary appliances”, the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2012, and conflicting national standards shall be withdrawn at the latest by March 2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 31:1998, EN 32:1998, EN 111:2003.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This European Standard specifies the connecting dimensions of wash basins in accordance with EN 14688 regardless of materials used for their manufacture.

NOTE 1 Other connecting dimensions are permitted, e.g. special designs of wash basins, if the manufacturer supplies or recommends the appropriate fitting.

NOTE 2 The shape of the appliance in the figures is for illustration only; it in no way prejudices the final shape of the appliance, which is left to the initiative of the manufacturer.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 14688, Sanitary appliances - Wash basins - Functional requirements and test methods

3 Tap holes

3.1 General

The connecting dimensions for tap holes are requirements for wash basins where it is intended to fit a tap.

3.2 Connecting dimensions of wash basins with one central tap hole

The connecting dimensions of wash basins with one central tap hole shall comply with Table 1.

Table 1 — Connecting dimensions of wash basins with one central tap hole (Figure 1)

Designation	Symbol	Dimensions mm
Diameter of the central tap hole (intended to accommodate a mixer tap)	d_2^a	35^{+2}_{-1}
Horizontal distance between the centre line of the central tap hole and the edge of the bowl	g_1	≤ 80
Distance from the centre line of the central tap hole to the back wall	g_3	≥ 55
Radius of a cylinder having the same centre line as the central tap hole at a depth 0 mm to 5 mm from the lower plane of the central tap hole	r_1	≥ 25
Radius of a cylinder having the same centre line as the central tap hole at a depth of minimum 5 mm from the lower plane of the central tap hole	r_2	≥ 30
Radius of a flat plane circular surface on the tap platform having the same centre as the central tap hole and intended to accommodate the tap	r_3	≥ 32
Thickness of the platform at the level of the zone concentric to the central tap hole	s	≤ 18
Horizontal distance between the centre line of the central tap hole and the centre line of the waste outlet hole	t^b	≤ 170
<p>^a The diameter 30^{+2}_0 is permissible with $r_1 \geq 22$ and $r_2 \geq 25$.</p> <p>^b May not be applicable for wash basins of class CL 00 in accordance with EN 14688.</p>		

Dimensions in millimetres




Figure 1 — Connecting dimensions of wash basins with one central tap hole

3.3 Connecting dimensions of wash basins with side tap hole(s)

The connecting dimensions of wash basins with one or two tap holes for side tap(s) shall comply with Table 2.

Table 2 — Connecting dimensions of wash basins with side tap hole(s) (Figure 2)

Designation	Symbol	Dimensions mm
Diameter of the tap hole(s) (intended to accommodate mixer tap(s))	d_2^a	35^{+2}_{-1}
Shortest horizontal distance between the centre line of the tap hole(s) and the edge of the bowl	g_2	≤ 65
Distance from the centre line of the tap hole(s) to the back wall	g_3	≥ 55
Radius of a cylinder having the same centre line as the tap hole at a depth 0 mm to 5 mm from the lower plane of the tap hole	r_1	≥ 25
Radius of a cylinder having the same centre line as the tap hole at a depth of minimum 5 mm from the lower plane of the tap hole	r_2	≥ 30
Radius of a flat plane circular surface on the tap platform having the same centre as the tap hole and intended to accommodate the tap	r_3	≥ 32
Thickness of the platform at the level of the zone concentric to the tap hole(s)	s	≤ 18
Horizontal distance between the centre line of the tap hole(s) and the centre line of the waste outlet hole	t^b	≤ 170
^a The diameter 30^{+2}_0 is permissible with $r_1 \geq 22$, $r_2 \geq 25$ and $r_3 \geq 30$ (intended to accommodate pillar tap(s)).		
^b May not be applicable for wash basins of class CL 00 in accordance with EN 14688.		




Figure 2 — Connecting dimensions of wash basins with two side tap holes

3.4 Connecting dimensions of wash basins with three tap holes

The connecting dimensions of wash basins with three tap holes shall comply with Table 3.

Table 3 — Connecting dimensions of wash basins with three tap holes (Figure 3)

Designation	Symbol	Dimensions mm
Diameter of outer tap holes	d_1	30^{+2}_0
Diameter of the central tap hole	d_2	35^{+2}_{-1}
Distance from the centre line of the central tap hole to the centre line of the two outer tap holes	e	0 to 15
Distance between the centre lines of the two outer tap holes	f	200 ± 4
Horizontal distance between the centre line of the central tap hole and the edge of the bowl	g_1	≤ 80
Distance from the centre line of the central tap hole to the back wall	g_3	≥ 55
Shortest horizontal distance between the centre lines of the outer tap holes and the edge of the bowl when only the two outer tap holes are used	g_4	≤ 65
Radius of a cylinder having the same centre line as the central tap hole at a depth 0 mm to 5 mm from the lower plane of the tap hole	r_1	≥ 25
Radius of a cylinder having the same centre line as the central tap hole at a depth of minimum 5 mm from the lower plane of the central tap hole	r_2	≥ 30
Radius of a flat plane circular surface on the tap platform having the same centre as the central tap hole and intended to accommodate the tap	r_3	≥ 32
Radius of a flat plane circular surface on the tap platform having the same centre as the outer tap holes and intended to accommodate the side valves	r_4	≥ 30
Thickness of the platform at the level of the zone concentric to the tap holes	s	≤ 18
Horizontal distance between the centre line of the central tap hole and the centre line of the waste outlet hole	t^a	≤ 170
^a May not be applicable for wash basins of class CL 00 in accordance with EN 14688.		

Dimensions in millimetres




Figure 3 — Connecting dimensions of wash basins with three tap holes

4 Waste outlet hole(s)

4.1 Connecting dimensions of waste outlet hole(s) with integral overflow

The connecting dimensions of the waste outlet hole(s) with integral overflow shall comply with the dimensions given in Table 4.

Table 4 — Connecting dimensions of the waste outlet hole with integral overflow (Figure 4)

Designation	Symbol	Dimension mm
Bore of the waste outlet hole	d_3	46^{+2}_{-3}
Diameter of the base for the seal between the waste outlet hole and the waste fitting	d_4	≥ 60
Reference diameter to measure the height of the waste outlet hole (h_1)	d_5	63
Height of the waste outlet hole measured between the reference diameter d_5 and the base for the seal	h_1	45^{0}_{-5}
Height measured between the reference diameter d_5 and the bottom of the bowl	h_2	≥ 2
Vertical distance between the tap platform and the base for the seal	p	≤ 250
Cone angle of the upper section of the waste outlet hole	α	$100^{\circ}^{0}_{-5}$




Figure 4 — Dimensions of the waste outlet hole for wash basins with integral overflow

NOTE To verify the connecting dimensions in accordance with Table 4, it is recommended to use a gauge in accordance with Annex A.

4.2 Connecting dimensions of waste outlet hole without integral overflow

The connecting dimensions of the waste outlet hole(s) without integral overflow shall comply with the dimensions given in Table 5.

Table 5 — Connecting dimensions of the waste outlet hole (s) without integral overflow (Figure 5)

Designation	Symbol	Dimension mm
Bore of the waste outlet hole	d_3	46^{+2}_{-3}
Diameter of the base for the seal between the waste outlet hole and the waste fitting	d_4	≥ 60
Reference diameter to measure the height of the waste outlet hole (h_3)	d_5	63
Height measured between the reference diameter d_5 and the bottom of the bowl	h_2	≥ 2
Height of the waste outlet hole measured between the reference diameter d_5 and the base for the seal	h_3^a	20^{+0}_{-5}
Cone angle of the upper section of the waste outlet hole	α	100^{+0}_{-5}
^a The height $h_3 = 45^{+0}_{-5}$ is permissible.		




Figure 5 — Dimensions of the waste outlet hole for wash basins without integral overflow

NOTE To verify the connecting dimensions in accordance with Table 5, it is recommended to use a gauge in accordance with Annex A.

5 Fixing dimensions of wall-hung wash basins

The fixing dimensions of wall-hung wash basins shall comply with the dimensions given in Table 6.

Table 6 — Fixing dimensions of wall-hung wash basins

Designation	Width of the wash basin mm	Figure	Symbol	Dimension mm
Horizontal distance between the centre lines of the two fixing holes	< 530	6	<i>n</i>	In accordance with the manufacturer's specification
	≥ 530 and ≤ 750			280 ± 10
	> 750	6, 7, 8, 9		280 ± 10
				In accordance with the manufacturer's specification
Smallest length of a fixing hole	< 530	6	<i>m</i> ₁	In accordance with the manufacturer's specification
	≥ 530			≥ 28
Smallest width of a fixing hole	< 530	6	<i>m</i> ₂	In accordance with the manufacturer's specification
	≥ 530			20 ± 2




Figure 6 — Fixing dimensions of wall-hung wash basins




Figure 7 — Example showing four fixing holes on a wash basin with two bowls having a width > 750 mm




Figure 8 — Example showing four fixing holes on a wash basin with one bowl having a width > 750 mm




Figure 9 — Example showing three fixing holes on a wash basin having a width > 750 mm

Annex A (informative)

Example of gauge for measuring the connecting dimensions of waste outlet holes

Dimensions in millimetres




Figure A.1 — Example of a gauge to verify the connecting dimensions of waste outlet holes with or without integral overflow

Copyright British Standards Institution
Provided by IHS under license with BSI - Uncontrolled Copy
No reproduction or networking permitted without license from IHS

This page deliberately left blank

Copyright British Standards Institution
Provided by IHS under license with BSI - Uncontrolled Copy
No reproduction or networking permitted without license from IHS

This page deliberately left blank

British Standards Institution (BSI)

BSI is the independent national body responsible for preparing British Standards and other standards-related publications, information and services.

It presents the UK view on standards in Europe and at the international level.

It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover.

Tel: +44 (0)20 8996 9001 Fax: +44 (0)20 8996 7001

BSI offers Members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Tel: +44 (0)20 8996 7669 Fax: +44 (0)20 8996 7001

Email: plus@bsigroup.com

Buying standards

You may buy PDF and hard copy versions of standards directly using a credit card from the BSI Shop on the website **www.bsigroup.com/shop**. In addition all orders for BSI, international and foreign standards publications can be addressed to BSI Customer Services.

Tel: +44 (0)20 8996 9001 Fax: +44 (0)20 8996 7001

Email: orders@bsigroup.com

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Knowledge Centre.

Tel: +44 (0)20 8996 7004 Fax: +44 (0)20 8996 7005

Email: knowledgecentre@bsigroup.com

Various BSI electronic information services are also available which give details on all its products and services.

Tel: +44 (0)20 8996 7111 Fax: +44 (0)20 8996 7048

Email: info@bsigroup.com

BSI Subscribing Members are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration.

Tel: +44 (0)20 8996 7002 Fax: +44 (0)20 8996 7001

Email: membership@bsigroup.com

Information regarding online access to British Standards via British Standards Online can be found at **www.bsigroup.com/BSOL**

Further information about BSI is available on the BSI website at **www.bsigroup.com/standards**

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. This does not preclude the free use, in the course of implementing the standard of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained. Details and advice can be obtained from the Copyright & Licensing Manager.

Tel: +44 (0)20 8996 7070

Email: copyright@bsigroup.com

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Tel +44 (0)20 8996 9001

Fax +44 (0)20 8996 7001

www.bsigroup.com/standards

raising standards worldwide™

Copyright British Standards Institution
Provided by IHS under license with BSI - Uncontrolled Copy
No reproduction or networking permitted without license from IHS

Not for Resale

