



DPC: 15 / 30296851 DC

**BSI Group Headquarters**

389 Chiswick High Road London W4 4AL

Tel: + 44 (0)20 8996 9000

Fax: + 44 (0)20 8996 7400

www.bsigroup.com

Date: 28 July 2015  
Origin: International**Latest date for receipt of comments: 28 September 2015**

Project No. 2014/00138

Responsible committee: FSH/18/2 Sprinkler Systems

Interested committees:

Title: Draft BS ISO 6182-14 Fire protection - Automatic sprinkler systems

Part 14: Requirements and test methods for water spray nozzles

Please notify the secretary if you are aware of any keywords that might assist in classifying or identifying the standard or if the content of this standard

- i) has any issues related to 3rd party IPR, patent or copyright
- ii) affects other national standard(s)
- iii) requires additional national guidance or information

**WARNING: THIS IS A DRAFT AND MUST NOT BE REGARDED OR USED AS A BRITISH STANDARD.  
THIS DRAFT IS NOT CURRENT BEYOND 28 September 2015**This draft is issued to allow comments from interested parties; all comments will be given consideration prior to publication. No acknowledgement will normally be sent. **See overleaf for information on the submission of comments.**

No copying is allowed, in any form, without prior written permission from BSI except as permitted under the Copyright, Designs and Patent Act 1988 or for circulation within a nominating organization for briefing purposes. Electronic circulation is limited to dissemination by e-mail within such an organization by committee members.

Further copies of this draft may be purchased from BSI Shop <http://shop.bsigroup.com> or from BSI Customer Services, Tel: + 44(0) 20 8996 9001 or email [cservices@bsigroup.com](mailto:cservices@bsigroup.com). British, International and foreign standards are also available from BSI Customer Services.Information on the co-operating organizations represented on the committees referenced above may be obtained from <http://standardsdevelopment.bsigroup.com>Responsible Committee Secretary: **Mrs Susan Revell (BSI)**  
Direct tel: **020 8996 7195**  
E-mail: [susan.revell@bsigroup.com](mailto:susan.revell@bsigroup.com)

## Introduction

This draft standard is based on international discussions in which the UK has taken an active part. Your comments on this draft are invited and will assist in the preparation of the consequent standard. Comments submitted will be reviewed by the relevant BSI committee before sending the consensus UK vote and comments to the international secretariat, which will then decide appropriate action on the draft and the comments received.

If the international standard is approved, it is possible the text will be published as an identical British Standard.

## UK Vote

Please indicate whether you consider the UK should submit a negative (with reasons) or positive vote on this draft.

## Submission of Comments

- The guidance given below is intended to ensure that all comments receive efficient and appropriate attention by the responsible BSI committee. **Annotated drafts are not acceptable and will be rejected.**
- All comments must be submitted, preferably electronically, to the Responsible Committee Secretary at the address given on the front cover. Comments should be compatible with version 6.0 or version 97 of Microsoft Word for Windows, if possible; otherwise comments in ASCII text format are acceptable. **Any comments not submitted electronically should still adhere to these format requirements.**
- All comments submitted should be presented as given in the example below. Further information on submitting comments and how to obtain a blank electronic version of a comment form are available from the BSI website at: <http://drafts.bsigroup.com/>

## Template for comments and secretariat observations

Date: xx/xx/20xx	Document: ISO/DIS xxxx
------------------	------------------------

1	2	(3)	4	5	(6)	(7)
MB	Clause No./ Subclause No./Annex (e.g. 3.1)	Paragraph/ Figure/ Table/Note	Type of comment	Comment (justification for change) by the MB	Proposed change by the MB	Secretariat observations on each comment submitted
	3.1	Definition 1	ed	Definition is ambiguous and needs clarifying.	Amend to read '...so that the mains connector to which no connection...'	
	6.4	Paragraph 2	te	The use of the UV photometer as an alternative cannot be supported as serious problems have been encountered in its use in the UK.	Delete reference to UV photometer.	

# DRAFT INTERNATIONAL STANDARD

## ISO/DIS 6182-14

ISO/TC 21/SC 5

Secretariat: ANSI

Voting begins on:  
2015-07-28

Voting terminates on:  
2015-10-28

---

---

### Fire protection — Automatic sprinkler systems —

#### Part 14:

### Requirements and test methods for water spray nozzles

*Protection contre l'incendie — Systèmes d'extinction automatiques du type sprinkler*

ICS: 13.220.20

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENT AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.



Reference number  
ISO/DIS 6182-14:2015(E)

© ISO 2015



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Ch. de Blandonnet 8 • CP 401  
CH-1214 Vernier, Geneva, Switzerland  
Tel. +41 22 749 01 11  
Fax +41 22 749 09 47  
copyright@iso.org  
www.iso.org

<b>Contents</b>	<b>Page</b>
Foreword .....	iv
Introduction.....	v
1 Scope .....	1
2 Normative References.....	1
3 Definitions .....	1
3.1 General .....	1
4 Product consistency .....	2
5 Product assembly.....	2
5.1 Design features.....	2
5.2 Materials of construction.....	2
6 Requirements.....	2
6.1 Dimensions .....	2
6.1.1 Orifice Size .....	2
6.1.2 Nominal thread sizes.....	2
6.2 Flow constant (see 7.2).....	2
6.3 Water distribution (see 7.3) .....	3
6.4 Stress Corrosion (see 7.4).....	3
6.4.1 Stress corrosion for copper alloy parts (see 7.4.1) .....	3
6.4.2 Stress corrosion for stainless steel parts (see 7.4.2) .....	3
6.5 Coated nozzles (see 7.5) .....	3
6.5.1 Evaporation of wax and bitumen (see 7.5.1).....	3
6.5.2 Resistance to low temperatures (see 7.5.2).....	3
6.5.3 Resistance to high temperature(see 7.5.3) .....	3
6.6 Resistance to heat (see 7.6) .....	4
6.7 Vibration (see 7.7).....	4
6.8 Impact (see 7.8).....	4
6.9 Strength of water dispersing components (see 7.9).....	4
7 Methods of test .....	4
7.1 Preliminary examination .....	4
7.1.1 Visual examination .....	4
7.2 Water flow constant (see 6.2).....	4
7.3 Water distribution tests (see 6.3).....	5
7.4 Stress corrosion tests (see 6.4) .....	7
7.4.1 Stress corrosion test with aqueous ammonia solution (see 6.4.1) .....	7
7.4.2 Stress corrosion test with a boiling magnesium chloride solution (see 6.4.2).....	7
7.5 Tests for nozzle coatings (see 6.5) .....	8
7.5.1 Evaporation test (see 6.5.1) .....	8
7.5.2 Low-temperature test (see 6.5.2) .....	8
7.5.3 High -temperature test (see 6.5.3).....	8
7.6 Resistance to heat test (see 6.6) .....	8
7.7 Vibration test (see 6.7) .....	8
7.8 Impact test (see 6.8) .....	9
7.9 Strength of water dispersing components test (see 6.9) .....	9
8 Marking .....	10
8.1 Nozzles .....	10
9 Manufacturer's installation instructions .....	10
Annex A .....	11

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 6182-1X was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 5, *Fixed firefighting systems using water*.

This second/third/... edition cancels and replaces the first/second/... edition (), [clause(s) / subclause(s) / table(s) / figure(s) / annex(es)] of which [has / have] been technically revised.

ISO 6182 consists of the following parts, under the general title *Fire protection — Automatic nozzle systems*:

- *Part 1: Requirements and test methods for nozzles*
- *Part 2: Requirements and test methods for wet alarm valves, retard chambers and water motor alarms*
- *Part 3: Requirements and test methods for dry pipe valves*
- *Part 4: Requirements and test methods for quick-opening devices*
- *Part 5: Requirements and test methods for deluge valves*
- *Part 6: Requirements and test methods for check valves*
- *Part 7: Requirements and test methods for Early Suppression Fast Response (ESFR) Nozzles*
- *Part 8: Requirements and test methods for pre-action dry alarm valves*
- *Part 9: Requirements and test methods for water mist nozzles*
- *Part 10: Requirements and test methods for domestic nozzles*
- *Part 11: Requirements and test methods for pipe hangers*
- *Part 12: Requirements and test methods for couplings for grooved end components for steel pipe systems*
- *Part 13: Requirements and test methods for extended coverage sprinklers*

## **Introduction**

These nozzles are intended for application of hazards involving exposure protection, the extinguishment or control of fires including flammable liquids hazards, conveyor openings, oil cooled transformers, dryers, and other hazards.



# Fire protection — Automatic nozzle systems — Part 1X: Requirements and test methods for water spray nozzles

## 1 Scope

This part of ISO 6182 specifies performance requirements, methods of test, and marking requirements for open water spray nozzles. This standard does not cover open sprinklers or open water mist nozzles.

Factors of installation such as nozzle spacing, design densities, wind and hot gas velocities are not intended to be addressed by this product standard.

## 2 Normative References

The following standards contain provisions which, through reference in this text, constitute provisions of this part of ISO 6182. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this part of ISO 6182 are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

ASTM G36 Standard Practice for Evaluating Stress-Corrosion-Cracking Resistance of Metals and Alloys in a Boiling Magnesium Chloride Solution

ISO 7-1:1982 Pipe threads where pressure-tight joints are made on the threads - Part 1: Designation, Dimension and Tolerances

ISO 49:1983 Malleable cast iron fittings threaded to ISO 7-1

ISO 65:1981 Carbon steel tubes suitable for screwing in accordance with ISO 7-1

## 3 Definitions

For the purposes of this International Standard, the following definitions apply:

### 3.1 General

#### 3.1.1

##### **open water spray nozzle**

A water spray nozzle that has no heat responsive element and discharges water after the water spray system is actuated.

#### 3.1.2

##### **water spray nozzle**

A water discharge device that, when discharging water under pressure, will distribute the water in a specific directional pattern.

#### 3.1.3

##### **water spray nozzles with deflector plates**

A water spray nozzle having a deflector plate.

### 3.1.4

#### **water spray nozzle with swirl chambers**

A water spray nozzle with one or more internal passages.

### 3.1.5

#### **Coated nozzle**

A water spray nozzle that has a factory-applied coating for corrosion protection.

NOTE For this document coated nozzle does not include coatings intended for aesthetic purposes.

## **4 Product consistency**

It shall be the responsibility of the manufacturer to implement a quality control program to ensure that production continuously meets the requirements of this part of ISO 6182.

## **5 Product assembly**

### **5.1 Design features**

All nozzles shall be designed and manufactured in such a way that they cannot be readily adjusted, dismantled or reassembled.

### **5.2 Materials of construction**

Nozzles shall be constructed of materials having corrosion resistance equivalent to brass, bronze or austenitic stainless steel.

## **6 Requirements**

### **6.1 Dimensions**

#### **6.1.1 Orifice Size**

**6.1.1.1** Except as permitted in 6.1.1.2, All nozzles shall be constructed so that a sphere of diameter 5 mm can pass through each water passage in the nozzle.

**6.1.1.2** Nozzles having orifices smaller than a nominal 5 mm diameter are permitted if the orifices are protected with a strainer in the system or in each nozzle. The maximum dimension of an opening in the strainer shall not exceed 80 % of the smallest water passageway being protected and the total open area of the strainer shall not be less than 150 % of the total nozzle orifice area.

Note: If there is no risk of corrosion or water deposits, then an orifice less than 5 mm could be used without a strainer. See the manufacturer's installation instruction requirements in Clause 9.

#### **6.1.2 Nominal thread sizes**

Nominal thread sizes should be suitable for fittings threaded in accordance with ISO 7-1. The dimensions of all threaded connections should conform to International Standards where applied or shall conform to national standards where International Standards are not applicable.

### **6.2 Flow constant (see 7.2)**

The flow constant,  $K$ , for nozzles is given by the formula:

$$K = \frac{q}{\sqrt{10p}}$$

where

$p$  is the pressure, expressed in megapascals;

$q$  is the flow rate, expressed in litres per minute;

K-factor for nozzles shall be in accordance with the manufacturer's design and installation instructions when determined by the test method given in 7.3. Each flow constant K (calculated), shall be within  $\pm 5\%$  of the manufacturer's value, for nozzles having a nominal k-factor of 40 or larger, and  $\pm 10\%$  of the manufacturer's value for nozzles having a nominal k-factor less than 40..

### **6.3 Water distribution (see 7.3)**

When tested as described in 7.3.1 through 7.3.3, a spray nozzle shall produce a spray angle within  $\pm 10^\circ$  of the manufacturer's published water discharge angles. Other methods of determining nozzle spray angle shall be permitted to be used provided the same level of accuracy is maintained. Stress Corrosion (see 7.4)

### **6.4 Stress Corrosion (see 7.4)**

#### **6.4.1 Stress corrosion for copper alloy parts (see 7.4.1)**

When tested in accordance with 7.4.1, each nozzle shall show no cracks, delamination or degradation which could affect its ability to satisfy other requirements of this standard.

#### **6.4.2 Stress corrosion for stainless steel parts (see 7.4.2)**

When tested in accordance with 7.4.2, each nozzle shall show no cracks, delamination or degradation which could affect its ability to satisfy other requirements of this standard.

Note: In some countries, this test is not mandatory.

### **6.5 Coated nozzles (see 7.5)**

#### **6.5.1 Evaporation of wax and bitumen (see 7.5.1)**

Waxes and bitumens used for coating nozzles shall not contain volatile matter in sufficient quantities to cause shrinkage, hardening, cracking or flaking of the applied coating. The loss in mass shall not exceed 5 % of that of the original sample when tested by the method in 7.5.1.

#### **6.5.2 Resistance to low temperatures (see 7.5.2)**

All coatings used for nozzles shall not crack or flake when subjected to low temperatures by the method in 7.5.2.

#### **6.5.3 Resistance to high temperature (see 7.5.3)**

Coated nozzles shall withstand exposure to increased ambient temperatures without evidence of cracking, flaking, delamination, deformation or melting of the coating, when tested by the method specified in 7.5.3.

## 6.6 Resistance to heat (see 7.6)

Nozzles shall be resistant to high temperatures when tested in accordance with 7.6. After exposure, the nozzle shall not fracture or break. If visual deformation is observed in the water discharge path, it shall meet the requirements of 6.2. If the nozzle is deformed, water distribution testing shall be conducted in accordance with 6.3.

## 6.7 Vibration (see 7.7)

Nozzles having multiple components shall be able to withstand the effects of vibration without deterioration when tested in accordance with 7.7. After the vibration test of 7.7, nozzles shall show no visible deterioration or loosening of components.

## 6.8 Impact (see 7.8)

Nozzles shall have adequate strength to withstand impacts associated with handling, transport and installation without deterioration of performance. After the impact test of 7.8.1; these nozzles shall show no fracture. If the nozzle is deformed, water distribution and strength testing shall be conducted in accordance with 6.3 and 6.9.

## 6.9 Strength of water dispersing components (see 7.9)

The nozzle shall not show any signs of visible deterioration or loosening of components after the test specified in 7.9. If damage is noted, water distribution testing shall be conducted in accordance with 6.3.

# 7 Methods of test

The following tests shall be carried out for each type of nozzle. Before testing, precise drawings of parts and the assembly shall be submitted together with the appropriate specifications. Tests shall be conducted at a room temperature of  $20\text{ °C} \pm 10\text{ °C}$ , unless other temperatures are indicated. Nozzles shall be tested with all the components required by their design and installation instructions. Unless otherwise stated, the tolerances given in Annex A shall apply.

## 7.1 Preliminary examination

The construction shall be examined to ensure that it complies with the requirements of clause 5.

### 7.1.1 Visual examination

Before testing, nozzles shall be examined visually with respect to the following points:

- a) marking,
- b) conformity of the nozzles with the manufacturer's drawings and specification,
- c) obvious defects.

## 7.2 Water flow constant (see 6.2)

The nozzle shall be mounted with a pressure gauge on a supply pipe as shown in Figure 1.


Four nozzles shall be tested. The frame arms and deflector of nozzles may be removed to facilitate testing provided this does not impact the flow constant.

The water flow shall be measured at pressures from minimum discharge pressure to the maximum discharge pressure referenced in the manufacturer's installation instructions. . In one series of tests, the pressure shall

be increased at intervals of 0,1 MPa (1 bar), and, in the other series, the pressure shall be decreased from the maximum discharge pressure at intervals of 0,1 MPa (1 bar) to the minimum discharge pressure.

The K-factor shall be calculated for each flowing pressure and the K-factor shall be averaged for each series of readings. Each calculated K-factor shall be within the limits specified in 6.2. During the test, pressures shall be corrected for differences in height between the gauge and the outlet orifice of the nozzle.

Dimensions in millimeters



Accuracy: pressure gauge  $\pm 2\%$ ; weighing machine  $\pm 1\%$ .

### Key

- 1 pressure gauge
- 2 steel tube, nominal internal diameter 40 mm, medium mass (in accordance with ISO 65)
- 3 tee fitting, see 7.3.2 (in accordance with ISO 49)
- 4 air bleed valve
- 5 nozzle
- 6 plug or cap

**Figure 1 — Typical water flow test apparatus**

## 7.3 Water distribution tests (see 6.3)

**7.3.1** For a nozzle intended to be installed at various orientation positions, the nozzle shall be tested at  $0^\circ$  (vertically downward) using the test method described in 7.3.2 and in positions indicated in the manufacturer's installation instructions using the test method described in 7.3.3. A sidewall nozzle shall be tested at  $90^\circ$  using the test method described in 7.3.2.

**7.3.2** A water spray nozzle is to be supplied with water at the minimum and maximum discharge pressure, through a tee fitting. The outlet of the tee fitting is to be the same size as the inlet for nozzles with nominal inlet sizes of 25 mm and smaller. Tee fittings are to be the same size as the nozzle inlet for nozzles with inlets larger than a nominal 25 mm. The nozzle is to be positioned at distances of 0,6 m and at a maximum installation height, as referenced in the manufacturer's installation instructions, above an array of 300 mm by 300 mm square collection pans as shown in Figure 2. Water is to be collected in a large enough area such that at least one row of perimeter collection pans has no pans with more than a trace amount of water collected after ten minutes of discharge. After a minimum ten-minute discharge, the water collection is to be measured. The spray angle is to be determined and compared to the manufacturer's installation instructions.

**7.3.3** A nozzle is to be supplied with water at the minimum and maximum discharge pressure, through a tee fitting. The outlet is to be the same size as the inlet for nozzles. The nozzle is to be positioned at distances of 0,6 m from a 3 m by 3 m dry surface (plane of protection), with the plane of protection positioned

perpendicular to the line between the nozzle and this plane, as shown in Figure 3 in positions as described in the manufacturer's installation instructions. Water from the nozzle is to be discharged for at least 30 seconds or the time required to exhibit a characteristic spray angle. The spray angle, as determined by visually observing the wetted surface of the plane, is to be compared to the manufacturer's installation instructions. The nozzle is then to be positioned 3 m or the maximum distance specified in the manufacturer's instructions from the plane of protection, whichever is less, and observations made for impingement of water on the plane of protection.





Figure 2 — Collection Pan Array



**Figure 3 — Nozzle Orientation**

## 7.4 Stress corrosion tests (see 6.4)

### 7.4.1 Stress corrosion test with aqueous ammonia solution (see 6.4.1)

Five nozzles shall be subjected to the following aqueous ammonia test.

Degrease the samples to be tested and then expose them for 10 d to a moist ammonia-air mixture in a glass container.

An aqueous ammonia solution, having a density of  $0,94 \text{ g/cm}^3$ , shall be maintained in the bottom of the container, approximately 40 mm below the bottom of the samples. A volume of aqueous ammonia solution corresponding to  $0,01 \text{ ml/cm}^3$  of the volume of the container will give approximately the following atmospheric concentrations: 35% ammonia, 5% water vapor, and 60% air.

The moist ammonia-air mixture shall be maintained as closely as possible at atmospheric pressure, with the temperature maintained at  $(34 + 2)^\circ\text{C}$ . Provision shall be made for venting the chamber via a capillary tube to avoid the build-up of pressure. Specimens shall be shielded from condensate drippage. The glass container shall be placed in an enclosure which shall be heated uniformly to prevent condensate on the test sample.

Nozzles showing cracking or delamination shall not show evidence of separation of permanently attached parts when subjected to the water flow at the rated pressure for 30 min.

### 7.4.2 Stress corrosion test with a boiling magnesium chloride solution (see 6.4.2)

7.4.2.1 Four sets of uncoated or unplated stainless steel components and four previously untested nozzles shall be degreased and then exposed to a boiling magnesium chloride solution for a period of 150 (+12, -0) hours as described below, and in accordance with ASTM G36, *Standard Practice for Evaluating Stress-Corrosion-Cracking Resistance of Metals and Alloys in a Boiling Magnesium Chloride Solution*. Special fixtures or elevated temperature operating elements may be employed to simulate assembly loading on parts, where appropriate and necessary.

**7.4.2.2** Samples are to be placed in a flask fitted with a wet condenser. The flask shall be filled approximately one-half full with magnesium chloride solution, placed on a thermostatically-controlled electrically-heated mantle, and maintained at a boiling temperature of  $150^{\circ}\text{C} \pm 2^{\circ}\text{C}$ .

Note: The nominal weight of magnesium chloride is 42 to 44 % in order to achieve the boiling temperature.

**7.4.2.3** Following exposure, the samples shall be removed and rinsed in potable water. Following a 2- to 4-day drying period, visual examination of the samples shall be made.

**7.4.2.4** The stainless steel components that show no evidence of cracking, delamination, or degradation shall not need further testing. Stainless steel components showing stress corrosion cracking or delamination shall not show evidence of separation of permanently attached parts when subjected to the water flow at rated pressure for 30 min.

## **7.5 Tests for nozzle coatings (see 6.5)**

### **7.5.1 Evaporation test (see 6.5.1)**

A 50 cm<sup>3</sup> sample of wax or bitumen shall be placed in a metal or glass cylindrical container, having a flat bottom, an internal diameter of 55 mm and an internal height of 35 mm. The container, without lid, shall be placed in an automatically controlled electric, constant ambient temperature oven with air circulation. The temperature in the oven shall be controlled at 16°C below the nominal release temperature of the nozzle, but at not less than 50°C. The sample shall be weighed before and after 90 d exposure to determine any loss of volatile matter; the sample shall meet the requirements of 6.5.1.

### **7.5.2 Low-temperature test (see 6.5.2)**

Five nozzles, coated by normal production methods, whether with wax, bitumen or a metallic coating, shall be subjected to a temperature of -10°C for a period of 24 h. On removal from the low temperature cabinet, the nozzles shall be allowed to return to normal ambient temperature for at least 30 minutes before examination of the coating to the requirements of 6.5.2.

### **7.5.3 High-temperature test (see 6.5.3)**

Twelve wax-coated nozzles shall be exposed to a constant temperature of 38 °C for low temperature wax and 66 °C for high temperature wax.

The test shall be conducted for 90 d. On removal from the exposure, the nozzles shall be allowed to return to normal ambient temperature for at least 30 min before examination of the coating to the requirements of 6.5.3.

## **7.6 Resistance to heat test (see 6.6)**

One nozzle body shall be heated in an oven at  $770^{\circ}\text{C} \pm 10^{\circ}\text{C}$  for a period of 15 minutes, with the nozzle on its inlet thread. The nozzle body shall then be removed, holding it by the threaded inlet, and shall be promptly immersed in a water bath at a temperature of approximately 15°C.

Note: In some countries, 650°C is used instead of 770°C for this test.

## **7.7 Vibration test (see 6.7)**

**7.7.1** Five nozzles shall be fixed vertically to a vibration table. They shall be subjected at room temperature to sinusoidal vibrations. The direction of vibration shall be along the axis of the connecting thread.


**7.7.2** The nozzles shall be vibrated continuously from 5 Hz to 40 Hz at a maximum rate of 5 minutes/octave and an amplitude of 1 mm (1/2 peak to peak value). If one or more resonant points are detected, the nozzles, after coming to 40 Hz, shall be vibrated at each of these resonant frequencies for 120 h per number of resonances. If no resonances are detected, the vibration from 5 Hz to 40 Hz shall be continued for 120 hours.

**7.7.3** After vibration, each nozzle shall be visually observed for evidence of deterioration or loosening of components.

### 7.8 Impact test (see 6.8)

**7.8.1** Five nozzles shall be impact-tested by dropping a weight onto the deflector or discharge end of the nozzle along the axial center line of the waterway. The mass equivalent to that of the tested nozzle shall be dropped from a height of 1 m (see Figure 4). The dropped weight shall be prevented from impacting more than once upon each sample

After the impact test, each nozzle shall meet the requirements of 6.8.



#### Key

- 1 cold drawn seamless steel tubing
- 2 mass
- 3 latching pin
- 4 adjustable brackets (2)
- 5 rigid support
- 6 nozzle support
- a Length to be determined (length of required mass).
- b Cold finished steel.

**Figure 4 — Impact test apparatus**

### 7.9 Strength of water dispersing components test (see 6.9)

The strength of the water dispersing components shall be verified using 3 nozzles at a pressure not less than the maximum rated pressure plus 0,17 MPa (1,7 bar). The water shall be allowed to flow at a residual pressure equal to not less than the rated pressure plus 0,17 MPa (1,7 bar) for a period of 30 min.

## 8 Marking

### 8.1 Nozzles

Each nozzle complying with the requirements of this International Standard shall be marked as follows:

- a) Identification of manufacturer, such as trademark, manufacturers name, or identifying symbol
- b) identification of model
- c) manufacturer's factory identification if the manufacturer has more than one nozzle manufacturing facility
- d) cone spray angle, if applicable
- e) nozzle K-factor
- f) nominal year of manufacture

**NOTE** The year of manufacture may include the last three months of the preceding year and the first six months of the following year.

Items a) through f) shall be permanently marked on the nozzle.

**Note** When there is not enough physical space to accommodate 8.1 f), alternate permanent marking methods may be used such as a tag.

## 9 Manufacturer's installation instructions

9.1 Manufacturer's installation instructions shall be available.

9.2 Those instructions shall include the following where applicable:

- a) flow constant;
- b) description of the spray pattern or patterns at various pressures and orientations;
- c) intended use pressure range;
- d) manufacturer's specified installation tool(s); and
- e) installation requirements related to 6.1.1.2 note.

**Annex A****(normative)****Tolerances**

Unless otherwise stated, the tolerances given in Table A.1 shall apply.

Table A.1 – Tolerances

<b>Parameter</b>	<b>Tolerance</b>	
Angle	$\pm 2^\circ$	
Length	$\pm 2\%$ of value	
Volume	$\pm 5\%$ of value	
Pressure	$\pm 3\%$ of value	
Temperature	$\pm 5\%$ of value	
Time	+5 0	seconds
	+0,1 0	minutes
	+0,1 0	hours
	+0,25 0	days